



CIVIL GEOTECHNICAL SERVICES
ABN 26 474 013 724
6-8 ROSE AVENUE, CROYDON 3136
(PO BOX 678 CROYDON 3136)
TELEPHONE + 61 3 9723 0744
FACSIMILE + 61 3 9723 0799
EMAIL nick.brock.civilgeotech@gmail.com

FILL CERTIFICATE

PROJECT: Lot No 901 (as per Drawing No 8584 E / 9)
Rothwell Estate – Stage 8, Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 18061_901

DATE: 25/01/18

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 901 of Rothwell Estate (Stage 9), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 18th September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



CIVIL GEOTECHNICAL SERVICES
ABN 26 474 013 724
6-8 ROSE AVENUE, CROYDON 3136
(PO BOX 678 CROYDON 3136)
TELEPHONE + 61 3 9723 0744
FACSIMILE + 61 3 9723 0799
EMAIL nick.brock.civilgeotech@gmail.com

FILL CERTIFICATE

PROJECT: Lot No 902 (as per Drawing No 8584 E / 9)
Rothwell Estate – Stage 8, Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 18061_902

DATE: 25/01/18

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 902 of Rothwell Estate (Stage 9), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 18th September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 914 (as per Drawing No 8584 E / 9)
Rothwell Estate – Stage 8, Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 18061_914

DATE: 25/01/18

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 914 of Rothwell Estate (Stage 9), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 18th September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



CIVIL GEOTECHNICAL SERVICES
ABN 26 474 013 724
6-8 ROSE AVENUE, CROYDON 3136
(PO BOX 678 CROYDON 3136)
TELEPHONE + 61 3 9723 0744
FACSIMILE + 61 3 9723 0799
EMAIL nick.brock.civilgeotech@gmail.com

FILL CERTIFICATE

PROJECT: Lot No 915 (as per Drawing No 8584 E / 9)
Rothwell Estate – Stage 8, Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 18061_915

DATE: 25/01/18

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 915 of Rothwell Estate (Stage 9), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 18th September 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock