



FILL CERTIFICATE

PROJECT: Lot No 306 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_306

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 306 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 307 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_307

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 307 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock', is written over a light blue circular stamp.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 308 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_308

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 308 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 309 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_309

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 309 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 310 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_310

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 310 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to read 'Nick Brock'.

Nick Brock



FILL CERTIFICATE

PROJECT: Lot No 311 (as per Drawing No 8584 E/4)
Rothwell (Stage 3), Truganina

CLIENT: Rokon Pty Ltd
1 / 75 River Street
RICHMOND VIC 3121

REPORT NO: 17622_311

DATE: 03/11/17

SUMMARY

Civil Geotechnical Services were engaged by Rokon Pty Ltd to provide inspection and testing services on the earthworks associated with Lot 311 of the Rothwell Estate (Stage 3), Truganina in a manner which would satisfy the criteria for Level 1 Supervision as specified in Section 8.2 of AS 3798 - Guidelines on Earthworks for Commercial and Residential Developments - 2007. The project was classified as Type 1/2 requiring a minimum density ratio of 95.0% (standard compactive effort) within the area of fill placement.

A site inspection was conducted prior to any fill being placed on the Lot. On the completion of earthworks and after examining the test results and the materials used, we are of the opinion that the filling procedure conducted by Rokon Pty Ltd satisfied the requirements of AS 3798 in regard to the placement of fill on a Type 1/2 Project under Level 1 Supervision.

Accordingly, when classifying the site in accordance with the procedures presented in Section 2 of AS 2870 – Residential Slabs and Footings – Construction (2011), we are of the view that the bulk fill materials that were placed on this Lot by Rokon Pty Ltd can be considered as being placed in a controlled manner to a minimum density ratio of 95% (standard compactive effort).

LIMITATIONS

The use of this Certificate is only appropriate for the field conditions present up to 1st July 2017.

A handwritten signature in blue ink, appearing to be 'Nick Brock'.

Nick Brock